2006 Fiesta Flambeau Night Parade
"Parade of Musical Reflections"
Saturday, April 29, 2006

SAN ANTONIO FIRE DEPARTMENT REQUIREMENTS

Each float entry will be charged a $20.00 (twenty dollar) inspection fee. This fee applies to all floats, **including military**, commercial, non-profit organizations. Check or money order must be made payable to the **City of San Antonio**.

All floats will be inspected prior to the parade by a member of the San Antonio Fire Marshal's Office for compliance with the below listed float requirements. Any float failing to comply with **any** of the following requirements will result in disqualification of that float.

San Antonio City Ordinances require all floats:

- To be constructed of flame retardant materials or the float and decorations must be sprayed with an approved (UL) flameproofing. (Note: floats will be tested) **NO HAY WILL BE ALLOWED. UFC 1104.1**

- Must have a minimum 2A10BC portable fire extinguisher that is readily accessible to the operator. The extinguisher must have a current inspection tag. **UFC 1104.2**

- The exhaust pipe of motorized floats must extend past the exterior of the float and be clear of all decorative materials. (this includes the exhaust of interior mounted portable generators.) **UFC 1104.3**
  Exterior mounted portable generators shall be mounted in such a manner as not to pose a fire threat to the float, its decorations, or its occupants.

- Motorized floats shall be equipped with a quick escape hatch for the interior driver compartment. **UFC 1104.4**

- **NO SMOKING IS ALLOWED ON OR IN FLOATS!**

Note that the fire extinguishers are now required to be at a minimum 2A10BC with a current inspection tag for the year.

If you have any questions, contact the Fire Marshal's Office at (210) 207-8410.
Lt. Larry Shipman